



Harker Heights Fire and Rescue – Office of the Fire Marshal

401 Indian Trail – Harker Heights, TX 76548
Phone (254) 699-2688 ~ Email: cmahlstedt@harkerheights.gov

Propane System Compliance Affidavit

Mobile Food Vender (MFV) Information

MFV Name: _____ MFV Owner: _____

License Plate: _____ VIN#: _____

Piping shall be tested annually at not less than 3 psig for 10 minutes before appliances are connected and at system pressure after connection by a licensed LP Gas Technician. Documentation of test, within 90 days of Health/Fire Inspection, must be provided at time of fire inspection.

Inspecting Individuals Information

Co. Name: _____ Inspector's Name: _____

Address: _____ Phone #: _____

RRC of TX License Type: _____ Inspector' RRC of TX License #: _____

Date of Inspection: _____

	Pass	Fail
System Plumbing	<input type="radio"/>	<input type="radio"/>
Appliances	<input type="radio"/>	<input type="radio"/>
Propane Tank	<input type="radio"/>	<input type="radio"/>
Pressure Leak / Test	<input type="radio"/>	<input type="radio"/>

By my signature below I swear and affirm that a leak test and inspection of the propane system was performed in accordance with the most current Railroad Commission of Texas adopted standards and the National Fire Protection Standard 58 – Liquefied Petroleum Gas Code. I hereby state that the information above is true, to the best of my knowledge.

Date: _____

Licensed Individual's Signature: _____